

Written Quiz

POINTS

1. List 3 types of roof openings suitable for ventilation 25

2. Why can forcible entry on automatic heat and smoke vents be dangerous? 25

3. Should heating, ventilating, and air conditioning systems be used for primary smoke control? 25

4. The operation and manual release features of automatic heat and smoke ventilation systems should be noted on a _____. 25

POINTS POSSIBLE: 100

POINTS DEDUCTED:

FINAL SCORE:

POINTS

1. List 3 types of roof openings suitable for ventilation 25
**ROOF STAIRWAYS, HATCHES, SKYLIGHTS,
VENTILATOR OPENINGS, ELEVATOR SHAFTS**

2. Why can forcible entry on automatic heat and smoke vents be dangerous? 25
CAN BE SPRING LOADED

3. Should heating, ventilating, and air conditioning systems be used for primary smoke control? 25
NOT IN MOST CASES

4. The operation and manual release features of automatic heat and smoke ventilation systems should be noted on a **PRE-PLAN**. 25

POINTS POSSIBLE: 100

POINTS DEDUCTED:

FINAL SCORE: